



Ref No: 054/2024/PMID/MCWAP2/RFB Addendum No.: 34

10 JULY 2024

**ABSTRACTION WORKS, PUMPING STATIONS, RESERVOIRS, PIPELINE, RELATED
MULTIDISCIPLINE WORKS, ANCILLARY WORKS**

ADDENDUM NO.: 34

Herewith please find Addendum No.:34 which forms an integral part of the above-mentioned contract.

PLEASE ACKNOWLEDGE RECEIPT OF THIS ADDENDUM AS FOLLOWS:

- 1. Complete the section below and **without delay** email a copy of this page to TCTA, email address tenders01@tcta.co.za; for the attention of The Receiving Officer to confirm that you have received this addendum.

Regards

.....

Azwi Nelwamondo
Senior Manager: Procurement



I/We herewith acknowledge receipt of ADDENDUM NO.:34 for CONTRACT NO. 054/2024/PMID/MCWAP2/RFB

SIGNATURE: DATE:

ON BEHALF OF:

ADDENDUM NO.:34

1. PART C3.1 – VOLUME 3 SPECIFICATION, SECTION 37 PAINTING AND CORROSION PROTECTION

The Polymer Modified Bitumen System as per Table 37/10 in Section 37 of the Specification is incorrect.

Ensure that the Polymer Modified Bitumen System enamel as per BS EN10300 Specification, Table 4 Category 2 Grade B is used, which will serve as the requirement to be met.